





Day-Brite / CFI T-Grid LED troffer is an energy efficient low profile luminaire offering excellent performance for general lighting applications such as offices, schools, healthcare, or retail. Featuring a frosted prismatic lens to enhance visual comfort, the T-Grid LED Troffer utilizes highly reliable and efficient Philips LED platform boards and dimmable driver, enabling market leading efficiency in its category.

# **Ordering guide**

# Example: 2TG32L840-4-FS-02F-UNV-DIM

Width	Family	Ceiling Type	Lumen Package	Color	Length	Door Frame	Lens	Voltage	Driver	Options
2	Т	G		_	4 -	_	_	_	_	
2 2'	T T-Grid LED troffer	<b>G</b> Grid	32L 3200 nominal delivered lumens 38L 3800 all delivered lumens 43L 4300 nominal delivered lumens 48L 4800 nominal delivered lumens 54L 5400 nominal delivered lumens 74L 7400 nominal delivered lumens	830 80 CRI, 3000K 835 80 CRI, 3500K 840 80 CRI, 4000K 850 80 CRI, 5000K	4 4'	FS Flat Steel FA Flat Aluminum RA Regressed Aluminum	O2F Pattern 12,100" nominal diffuse 50% 12F DB 12, 125" nominal diffuse 50% 19F DB 19, 156" nominal diffuse 50%	UNV Universal Voltage 120-277V 347 347V	DIM 0-10V dimming SDIM¹ Step dimming to 40% input power	F1 3/8" flex, 3 wire, 18 gauge 6' F2 3/8" flex, 4 wire, 18 gauge 6' F1/D 3/8" flex, 4 wire, 18 gauge 6' for dimmable luminaires F2/5W 3/8" single flex, 5 wire, 18 gauge 6', for dimmable luminaires EMLED <sup>2,3</sup> lintegral emergency battery pack 1W 1-way gasket between lens & door frame (not avail. for RA door frame) 2W 1-way & gasket between door frame & housing 3W 2-way & gasket betweem housing & ceiling (field installed) GLR Fusing, fast blow CHIC Chicago Plenum rated DSC Quick driver disconnect

#### **Footnotes**

- 1 SDIM not available with 74L lumen option
- 2 Not available for 74L-347V
- 3 1100 nominal lumens delivered in DC mode

# **Accessories (order separately)**

- FMA24 2'x4' "F" mounting frame for NEMA "F" mounting
- FKTG824 Flange conversion kit, 2'x4'





3200, 3800, 4300, 4800, 5400, or 7400 lumens

#### **Application**

- High efficacy long life solid state lighting platform.
- General lighting distribution is excellent for ambient lighting.
- High CRI source provides excellent color rendering.
- LEDs are an excellent source for use with controls since frequent switching does not affect the life of the light source.

#### Construction/finish

- A quality low-profile troffer with specification features for NEMA "G" grid, NEMA "NFG" narrow face grid, NEMA "GR" grid regressed, or NEMA "F" flange ceiling types.
- 3" nominal housing depth, 3-3/16" maximum depth.
- Smooth rolled edges on all four sides for easy handling.
- Die-formed one piece housing includes stiffening embosses and provides increased rigidity.
- Housing is multi-stage phosphate treated for maximum corrosion resistance and finish coat is high reflectance baked white enamel.
- · Integral baffling system to prevent light leaks.

- 2 sets of integral grid clips (wraparound and fold-out) for maximum mounting flexibility.
- Integral wire hanger holes for independent wire suspension.
- Embosses with holes provided in housing end for screwing to T-bar if desired.
- 7/8" K.O.'s provided in each end cap for through wiring.
- Factory installed access plate in housing top includes 7/8" hole with rolled edge and 7/8"
   K O
- Carton includes integral carrying handle for easy handling.

#### **Electrical**

- · Standard 0-10V dimming.
- Driver and LED boards are accessible from below. LED boards are individually replaceable if required.
- Five-year luminaire limited warranty including LED boards and driver. Visit www.philips. com/warranties for complete warranty information.
- High efficiency LEDs have 50,000 hour rated life (defined by testing at 70% lumen maintenance (L70)), based on 25°C ambient operating temperature.

- cETLus listed to UL and CSA standards, suitable for damp location.
- T-Grid LED luminaires are DesignLights Consortium® qualified. Please see the DLC QPL list for exact catalog numbers (http://www.designlights.org/QPL).
- Many luminaire components, such as reflectors, refractors, lenses, sockets, lampholders, and LEDs are made from various types of plastics which can be adversely affected by airborne contaminants. If sulfur based chemicals, petroleum based products, cleaning solutions, or other contaminants are expected in the intended area of use, consult factory for compatibility.


#### **Enclosure**

- Full "C" channel door frames for improved lens support and reduced shipping damage.
- Flat steel door frame features smooth rolled edges inside and outside.
- · All door frames have mitered corners.
- All door frames use T-hinges and can be hinged and latched from either side.
- Opposable spring loaded latches are standard for easy operation and consistent retention.


#### **Dimensions**



\*EMLED option adds 1-3/4" to overall height



Wraparound Grid Clips



Fold-Out Grid Clips

3200, 3800, 4300, 4800, 5400, or 7400 lumens

# **Photometry**

# 2x4 T-Grid LED troffer, 3200 nominal delivered lumens

# **LER - 112**

		Candle	power			Light	Distrib	ution			Ave	erage Lu	minan	ce
Catalog No.	2TG32L840-4-FS-02F-UNV	Angle	End	45	Cross	Degre	es L	umens	% Lumii	naire	Angl	e End	45°	Cross
Test No.	33527	0	1293	1293	1293	0-30		993	32.3		45	1646	1537	1415
S/MH	1.2	5	1291	1287	1284	0-40 0-60		1588 2564	51.7 83.5		55 65		1206 911	1082 874
Lamp Type	LED	15 25 35	1246 1143 973	1240 1123 938	1224 1095 892	0-90		3070	100.		75 85	962	815 828	848 655
Lumens	3071	45	746	697	641	Cooffi	cionts	of Liti	lization					
Input Watts	27.4	55	500	443	398									
		65	294	247	237		VE FLOOF		REFLECTA	NCE 20 P		0.20)	_	
Comparative yea	arly lighting energy cost per 1000	75 85	160 62	135 46	141 37	pcc	70	80	20	70	70	20	50	
	pased on 3000 hrs. and \$.08 pwr	00	02	40	37	pw RCR	70	50	30	70	50	30	50	30
KWH.	asca on 3000 ms. and 5.00 pwi					0	118	118	118	115	115	115	111	111
14441.						1	109	105	101	107	103	98	97	94
The photometric	results were obtained in the					2	100	92	85	97	91	84	86	81
	tory which is NVLAP accredited by					3	92	81	73	90	80	72	78	70
	itute of Standards and Technology.					4	84	72	65	81	71	64	69	63
	5,					5	78	66	56	76	65	56	63	56
	ues based on test performed in					7	72 67	59 54	51 46	70 66	58 54	51 46	56 52	50 45
compliance with	LM-79.					8	63	50	41	60	48	40	47	40
						9	58	46	38	57	45	38	44	36
						10	55	42	34	54	41	34	40	34

# 2x4 T-Grid LED troffer, 3800 nominal delivered lumens

#### LER - 111

		Candlepower					Distrib	oution		Average Luminance					
Catalog No.	2TG38L840-4-FS-02F-UNV	Angle	End	45	Cross	Degre	es I	Lumens	% Lumir	naire	Angle	e End	45°	Cross	
Test No.	33528	0	1542	1542	1542	0-30		1184	32.4		45	1917	1892	1868	
S/MH	1.2	5	1535	1537	1538	0-40 0-60		1894 3055	51.8 83.5		55 65	1581 1267	1519 1182	1499 1214	
Lamp Type	LED	15 25	1477 1349	1481 1352	1481 1348	0-90		3657	100.0		75	1132	1067	1189	
Lumens	3660	35	1142	1139	1131						85	1233	1214	1407	
nput Watts	33	45 55	868 581	857 558	846 551	Coeffi	cients	of Uti	lization						
iliput watts	33	65	343	320	329	EFFECTI	VE FLOO	R CAVITY	REFLECTA	NCE 20 P	ER (pfc=	0.20)			
Camanavativa	why lighting analysis sast nor 1000	75	188	177	197	pcc		80			70		50		
	arly lighting energy cost per 1000	85	69	68	79	pw	70	50	30	70	50	30	50	30	
	pased on 3000 hrs. and \$.08 pwr					RCR									
KWH.						0	118	118	118	115	115	115	111	111	
						1	109	105 92	101 85	107	103 91	98	97	94	
	results were obtained in the					2	100 92	81	73	97 90	80	72 72	86 78	81 70	
	tory which is NVLAP accredited by					3	84	72	65	81	71	64	69	63	
ne National Inst	itute of Standards and Technology.					5	78	66	56	76	65	56	63	56	
Photomotric valu	ues based on test performed in					6	72	59	51	70	58	51	56	50	
compliance with						7	67	54	46	66	54	46	52	45	
ompliance with	LIVI 75.					8	63	50	41	60	48	40	47	40	
						9	58	46	38	57	45	38	44	36	
						10	55	42	34	54	41	34	40	34	

3200, 3800, 4300, 4800, 5400, or 7400 lumens

# **Photometry**

# 2x4 T-Grid LED troffer, 4300 nominal delivered lumens

# **LER - 109**

		Candle	power			Light	Distrib	ution			Ave	erage Lu	minan	ce
Catalog No.	2TG43L840-4-FS-02F-UNV	Angle	End	45	Cross	Degre	ees L	umens	% Lumii	naire	Angl	e End	45°	Cross
Test No.	33530	0	1764	1764	1764	0-30		1354	32.3	3	45	2191	2163	2136
S/MH	1.2	5	1756	1757	1759	0-40 0-60		2166 3495	51.7 83.5		55 65		1735 1347	1714 1389
Lamp Type	LED	15 25 35	1690 1544 1304	1694 1546 1302	1694 1542 1294	0-90		4188	100.		75 85	1293	1219 1381	1362 1620
Lumens	4189	45	992	980	968	Cooffi	cionts	of Liti	lization					
Input Watts	38.4	55	663	637	630	Coeiii	Clerits	OI Oti	lization					
		65	392	365	376		IVE FLOOF		Y REFLECTA	NCE 20 P		0.20)		
Comparativo voa	rly lighting energy cost per 1000	75	214	202	226	pcc		80			70		5	
	pased on 3000 hrs. and \$.08 pwr	85	79	77	90	pw RCR	70	50	30	70	50	30	50	30
KWH.	based off 5000 fills. and 3.00 pwi					0	118	118	118	115	115	115	111	111
KWII.						1	109	105	101	107	103	98	97	94
The photometric	results were obtained in the					2	100	92	85	97	91	84	86	81
	ory which is NVLAP accredited by					3	92	81	73	90	80	72	78	70
	tute of Standards and Technology.					4	84	72	65	81	71	64	69	63
the mational moti	tate of Starragras and Teermology.					5	78	66	56	76	65	56	63	56
Photometric valu	es based on test performed in					6	72	59	51	70	58	51	56	50
compliance with	LM-79.					/	67 63	54 50	46 41	66 60	54 48	46 40	52 47	45 40
						9	58	46	38	57	45	38	44	36
						10	55	42	34	54	41	34	40	34

# 2x4 T-Grid LED troffer, 4800 nominal delivered lumens

#### **LER - 107**

		Candle	power			Light	Distrik	oution			Ave	rage Lui	minan	ce
Catalog No.	2TG48L840-4-FS-02F-UNV	Angle	End	45	Cross	Degre	ees l	Lumens	% Lumir	naire	Angle	e End	45°	Cross
Test No.	33531	0	1950	1950	1950	0-30		1498	32.3		45	2423	2392	2366
S/MH	1.2	5	1942	1943	1945	0-40 0-60		2395 3866	51.7 83.5		55 65	1997 1602	1919 1492	1899 1538
Lamp Type	LED	15 25	1868 1707	1872 1709	1874 1705	0-90		4632	100.0		75	1433	1353	1506
Lumens	4633	35	1443	1440	1430						85	1571	1542	1811
Input Watts	43.2	45 55	1098 734	1084 705	1072 698	Coeffi	icients	of Uti	lization					
input watts	43.2	65	434	404	417	EFFECT	IVE FLOO	R CAVITY	REFLECTA	NCE 20 P	ER (pfc=	0.20)		
Commonative	arly lighting analysis ast nov 1000	75	238	224	250	рсс		80			70	·	50	
	arly lighting energy cost per 1000	85	88	86	101	pw	70	50	30	70	50	30	50	30
	based on 3000 hrs. and \$.08 pwr					RCR								
KWH.						0	118	118	118	115	115	115	111	111
						1	109 100	105 92	101 85	107 97	103 91	98 84	97 86	94 81
	results were obtained in the					2	92	81	73	90	80	72	78	70
	atory which is NVLAP accredited by					4	84	72	65	81	71	64	69	63
the National inst	titute of Standards and Technology.					5	78	66	56	76	65	56	63	56
Photometric valu	ues based on test performed in					6	72	59	51	70	58	51	56	50
compliance with						7	67	54	46	66	54	46	52	45
compliance with	,					8	63	50	41	60	48	40	47	40
						9	58	46	38	57	45	38	44	36
						10	55	12	3.4	5/	<b>/11</b>	3/1	40	3/

3200, 3800, 4300, 4800, 5400, or 7400 lumens

### **Photometry**

#### 2x4 T-Grid LED troffer, 5400 nominal delivered lumens

# **LER - 105**

		Candle	power			Light	Distrib	ution			Ave	erage Lu	minan	ce
Catalog No.	2TG54L840-4-FS-02F-UNV	Angle	End	45	Cross	Degre	es L	umens	% Lumii	naire	Angl	e End	45°	Cross
Test No.	33532	0	2180	2180	2180	0-30		1674	32.3		45		2677	2643
S/MH	1.2	5	2171	2172	2174	0-40 0-60		2677 4322	51.7 83.5		55 65		2151 1673	2123 1721
Lamp Type	LED	15 25 35	2088 1907 1614	2094 1911 1609	2093 1905 1599	0-90		5177	100.		75	1603	1508 1710	1688 1988
Lumens Input Watts	5179 49.3	45 55	1227 820	1213 791	1197 780	Coeffic	cients	of Uti	lization					
		65	485	453	466		VE FLOOF		Y REFLECTA	NCE 20 P		0.20)		
Comparative yea	arly lighting energy cost per 1000	75 85	266 98	250 96	280 111	рсс	70	80	30	70	70	20	50	_
	based on 3000 hrs. and \$.08 pwr	65	98	96	1111	pw RCR	70	50	30	70	50	30	50	30
KWH.	based on 5000 ms. and 5.00 pwi					0	118	118	118	115	115	115	111	111
						1	109	105	101	107	103	98	97	94
The photometric	results were obtained in the					2	100	92	85	97	91	84	86	81
Day-Brite labora	tory which is NVLAP accredited by					3	92	81	73	90	80	72	78	70
the National Inst	titute of Standards and Technology.					5	84 78	72 66	65 56	81 76	71 65	64 56	69 63	63 56
Dhatamatriavalı	use based on test newformed in					6	72	59	51	70	58	51	56	50
compliance with	ues based on test performed in					7	67	54	46	66	54	46	52	45
compliance with	LIVI 73.					8	63	50	41	60	48	40	47	40
						9	58	46	38	57	45	38	44	36
						10	55	42	34	54	41	34	40	34

#### 2x4 T-Grid LED troffer, 7400 nominal delivered lumens

#### **LER - 96**

		Candle	power			Light	Distrib	ution			Ave	erage L	uminan	ce
Catalog No.	2TG74L840-4-FS-02F-UNV	Angle	End	45	Cross	Degre	es L	umens	% Lumir	naire	Angl	e End	l 45°	Cross
Test No.	33536	0	3008	3008	3008	0-30		2309	32.3		45			3643
S/MH	1.2	5	2994	2997	2999	0-40 0-60		3692 5959	51.7 83.5		55 65			2928 2378
Lamp Type	LED	15 25	2879 2628	2887 2634	2888 2627	0-90		7140	100.0		75	2210	2076	2330
Lumens	7142	35 45	2224 1689	2217 1669	2205 1650	C (C		C 1 111	11		85	241	1 2360	2783
Input Watts	74.1	55	1129	1089	1076	Соет	cients	of Uti	lization					
		65	669	624	644	EFFECTI	VE FLOO	R CAVIT	Y REFLECTA	NCE 20 P	ER (pfc:	0.20)		
Comparative ves	arly lighting energy cost per 1000	75	366	344	386	рсс		80			70			50
	based on 3000 hrs. and \$.08 pwr	85	135	132	155	pw	70	50	30	70	50	30	50	30
KWH.	based on 3000 firs. and 3.06 pwi					RCR	110	110	110	11.5	11.5	115	111	111
NVVΠ.						0	118 109	118 105	118 101	115 107	115 103	115 98	111 97	111 94
The section 4 - 4 - 4 - 4 - 4 - 4 - 4 - 4 - 4 - 4						2	100	92	85	97	91	84	86	94 81
	results were obtained in the tory which is NVLAP accredited by					3	92	81	73	90	80	72	78	70
	itute of Standards and Technology.					4	84	72	65	81	71	64	69	63
the National Inst	itute of Staridards and Technology.					5	78	66	56	76	65	56	63	56
Photometric valu	ues based on test performed in					6	72	59	51	70	58	51	56	50
compliance with						7	67	54	46	66	54	46	52	45
						8	63	50	41	60	48	40	47	40
						9	58	46	38	57	45	38	44	36
						10	55	42	34	54	41	34	40	34

